

# Injector Selection Table for High Natural Gas

Gas at 25 Lbs. Pressure; Approximate Mixture Pressure of 1.8" w.c.\*; 1245 B.T.U.; .71 Specific Gravity; 11.7 Air-Gas Ratio

Based on 100% Air Entrainment thru Injector

Capacity CF/HR at 25 Lbs.	Catalog Number  Injectors	Suggested burner area in square inches when using various types of burners at coefficient of discharge shown				100% Coefficient Discharge Burner
		Walltites 125%	Drilled Round Nose 87%	Sticktite or Ferrofix 75%	Blast Tips 60%	
25	H44 —72	.112	.16	.187	.234	.14
50	H54 —65	.22	.315	.365	.457	.274
75	H54 —57	.332	.477	.554	.692	.415
100	H65 —55	.480	.690	.80	1.000	.60
125	H65 —54	.526	.756	.880	1.10	.659
150	H86 —53	.64	.920	1.07	1.33	.8
175	H86 —51	.80	1.15	1.334	1.67	1.0
200	H86 —50	.87	1.25	1.45	1.82	1.09
250	H108 —47	1.12	1.61	1.87	2.34	1.4
300	H108 —44	1.33	1.90	2.21	2.77	1.66
350	H108 —42	1.58	2.26	2.63	3.28	1.97
400	H108 —39	1.78	2.57	2.98	3.72	2.23
450	H1210—36	2.05	2.95	3.43	4.29	2.57
500	H1210—35	2.17	3.13	3.63	4.54	2.72
550	H1210—32	2.43	3.5	4.06	5.06	3.04
600	H1210—31	2.60	3.84	4.32	5.40	3.24
650	H1612—30	2.97	4.27	4.96	6.20	3.72
700	H1612—29	3.32	4.76	5.54	6.90	4.15
750	H1612—28	3.54	5.1	5.90	7.40	4.43
800	H1612—28	3.54	5.1	5.90	7.40	4.43
850	H1612—27	3.72	5.36	6.24	7.80	4.67
900	H1612—26	4.00	5.75	6.68	8.35	5.00
950	H1612—23	4.26	6.12	7.10	8.90	5.33
1000	H1612—22	4.40	6.31	7.35	9.20	5.50
1100	H2016—19	5.95	7.10	8.25	10.30	6.19
1200	H2016—1 1/4	5.30	7.65	8.86	11.10	6.65
1300	H2016—15	5.80	8.35	9.65	12.10	7.26
1400	H2016—13	6.15	8.85	10.3	12.83	7.70
1600	H2016—10	6.71	9.65	11.2	14.00	8.40
1800	H2420—3	8.15	11.75	13.6	17.00	10.20
2000	H2420—2	8.80	12.6	14.7	18.40	11.00
2250	H2420—1 1/4	9.75	14.15	16.4	20.50	12.3
2500	H2420—E	11.20	16.10	18.7	23.40	14.0
2750	H2420—G	12.20	17.60	20.4	25.60	15.3
3000	H2420—I	13.30	19.10	22.1	27.80	16.6

\*Mixture Pressure:—The Mixture Pressure that can be developed will vary depending on piping conditions and draft and will vary directly with changes in Gas Pressure.

## CORRECTION FACTORS FOR CAPACITIES AT OTHER THAN 25 LBS. PRESSURE

Pounds Pressure.....	1	2	3	4	5	6	7	8	9	10	11	12	13
Correction Factor....	.20	.283	.346	.400	.467	.490	.530	.565	.600	.631	.664	.793	.721

Pounds Pressure.....	14	15	16	17	18	19	20	21	22	23	24	25
Correction Factor....	.748	.775	.800	.825	.850	.881	.895	.915	.938	.96	.98	1.00





**Offered By:**

Power Equipment Company  
2011 Williamsburg Road  
Richmond, Virginia 23231  
Phone (804) 236-3800  
Fax (804) 236-3882

---

[www.peconet.com](http://www.peconet.com)